

April 17, 2026

Justin Calhoun
120Water
250 South Elm St.
Zionsville, Indiana 46077

Re: Virginia Department of Health
Work Order: 772045

Dear Justin Calhoun:

GEL Laboratories, LLC (GEL) appreciates the opportunity to provide the enclosed analytical results for the sample(s) we received on April 09, 2026. This original data report has been prepared and reviewed in accordance with GEL's standard operating procedures.

The samples were delivered with proper chain of custody documentation and signatures. All sample containers arrived without any visible signs of tampering or breakage. There are no additional comments concerning sample receipt.


Test results for NELAP or ISO 17025 accredited tests are verified to meet the requirements of those standards, with any exceptions noted. The results reported relate only to the items tested and to the sample as received by the laboratory. These results may not be reproduced except as full reports without approval by the laboratory. Copies of GEL's accreditations and certifications can be found on our website at www.gel.com.

Our policy is to provide high quality, personalized analytical services to enable you to meet your analytical needs on time every time. We trust that you will find everything in order and to your satisfaction. If you have any questions, please do not hesitate to call me at (843) 556-8171, ext. 4705.

Sincerely,

Abigail Martin
Project Manager

Purchase Order: PO
Enclosures



GEL LABORATORIES LLC

2040 Savage Road Charleston SC 29407 - (843) 556-8171 - www.gel.com

Certificate of Analysis Report for

120W002 120 Water Inc.

Client SDG: 772045 GEL Work Order: 772045


The Qualifiers in this report are defined as follows:

- * A quality control analyte recovery is outside of specified acceptance criteria
- ** Analyte is a Tracer compound
- ** Analyte is a surrogate compound
- U Analyte was analyzed for, but not detected above the MDL, MDA, MDC or LOD.

Where the analytical method has been performed under NELAP certification, the analysis has met all of the requirements of the NELAC standard unless qualified on the Certificate of Analysis.

The designation ND, if present, appears in the result column when the analyte concentration is not detected above the limit as defined in the 'U' qualifier above.

This data report has been prepared and reviewed in accordance with GEL Laboratories LLC standard operating procedures. Please direct any questions to your Project Manager, Abigail Martin.



Reviewed by _____

GEL LABORATORIES LLC

2040 Savage Road Charleston SC 29407 - (843) 556-8171 - www.gel.com

Certificate of Analysis

Company : 120Water
Address : 250 South Elm St.
Zionsville, Indiana 46077

Report Date: April 17, 2026

Contact: Justin Calhoun
Project: **Virginia Department of Health**

Client Sample ID: 499580
Sample ID: 772045001
Matrix: Drinking Water (Potable)
Collect Date: 02-APR-26 07:23
Receive Date: 09-APR-26
Collector: Client

Project: 120W00624
Client ID: 120W002

Parameter	Qualifier	Result	RL	Units	PF	DF	Analyst	Date	Time	Batch	Method
Metals Analysis-ICP-MS											
<i>Lead, Total "As Received"</i>											
Lead	<	2.00	2.00	ug/L	1.00	1	JD2	04/15/26	1834	2976417	1

The following Prep Methods were performed:

Method	Description	Analyst	Date	Time	Prep Batch
EPA 200.2	ICP-MS 200.2 PREP	ES3	04/13/26	1000	2976416

The following Analytical Methods were performed:

Method	Description	Analyst Comments
1	EPA 200.8	

GEL LABORATORIES LLC

2040 Savage Road Charleston SC 29407 - (843) 556-8171 - www.gel.com

Certificate of Analysis

Company : 120Water
Address : 250 South Elm St.
Zionsville, Indiana 46077

Report Date: April 17, 2026

Contact: Justin Calhoun
Project: **Virginia Department of Health**

Client Sample ID: 499581
Sample ID: 772045002
Matrix: Drinking Water (Potable)
Collect Date: 02-APR-26 07:24
Receive Date: 09-APR-26
Collector: Client

Project: 120W00624
Client ID: 120W002

Parameter	Qualifier	Result	RL	Units	PF	DF	Analyst	Date	Time	Batch	Method
Metals Analysis-ICP-MS											
<i>Lead, Total "As Received"</i>											
Lead	<	2.00	2.00	ug/L	1.00	1	JD2	04/15/26	1839	2976417	1

The following Prep Methods were performed:

Method	Description	Analyst	Date	Time	Prep Batch
EPA 200.2	ICP-MS 200.2 PREP	ES3	04/13/26	1000	2976416

The following Analytical Methods were performed:

Method	Description	Analyst Comments
1	EPA 200.8	

GEL LABORATORIES LLC

2040 Savage Road Charleston SC 29407 - (843) 556-8171 - www.gel.com

Certificate of Analysis

Company : 120Water
Address : 250 South Elm St.
Zionsville, Indiana 46077

Report Date: April 17, 2026

Contact: Justin Calhoun
Project: **Virginia Department of Health**

Client Sample ID: 499582
Sample ID: 772045003
Matrix: Drinking Water (Potable)
Collect Date: 02-APR-26 07:24
Receive Date: 09-APR-26
Collector: Client

Project: 120W00624
Client ID: 120W002

Parameter	Qualifier	Result	RL	Units	PF	DF	Analyst	Date	Time	Batch	Method
Metals Analysis-ICP-MS											
<i>Lead, Total "As Received"</i>											
Lead	<	2.00	2.00	ug/L	1.00	1	JD2	04/15/26	1840	2976417	1

The following Prep Methods were performed:

Method	Description	Analyst	Date	Time	Prep Batch
EPA 200.2	ICP-MS 200.2 PREP	ES3	04/13/26	1000	2976416

The following Analytical Methods were performed:

Method	Description	Analyst Comments
1	EPA 200.8	

GEL LABORATORIES LLC

2040 Savage Road Charleston SC 29407 - (843) 556-8171 - www.gel.com

Certificate of Analysis

Company : 120Water
Address : 250 South Elm St.
Zionsville, Indiana 46077

Report Date: April 17, 2026

Contact: Justin Calhoun
Project: **Virginia Department of Health**

Client Sample ID: 499583
Sample ID: 772045004
Matrix: Drinking Water (Potable)
Collect Date: 02-APR-26 07:25
Receive Date: 09-APR-26
Collector: Client

Project: 120W00624
Client ID: 120W002

Parameter	Qualifier	Result	RL	Units	PF	DF	Analyst	Date	Time	Batch	Method
Metals Analysis-ICP-MS											
<i>Lead, Total "As Received"</i>											
Lead	<	2.00	2.00	ug/L	1.00	1	JD2	04/15/26	1842	2976417	1

The following Prep Methods were performed:

Method	Description	Analyst	Date	Time	Prep Batch
EPA 200.2	ICP-MS 200.2 PREP	ES3	04/13/26	1000	2976416

The following Analytical Methods were performed:

Method	Description	Analyst Comments
1	EPA 200.8	

GEL LABORATORIES LLC

2040 Savage Road Charleston SC 29407 - (843) 556-8171 - www.gel.com

Certificate of Analysis

Company : 120Water
Address : 250 South Elm St.
Zionsville, Indiana 46077

Report Date: April 17, 2026

Contact: Justin Calhoun
Project: **Virginia Department of Health**

Client Sample ID: 499584
Sample ID: 772045005
Matrix: Drinking Water (Potable)
Collect Date: 02-APR-26 07:25
Receive Date: 09-APR-26
Collector: Client

Project: 120W00624
Client ID: 120W002

Parameter	Qualifier	Result	RL	Units	PF	DF	Analyst	Date	Time	Batch	Method
Metals Analysis-ICP-MS											
<i>Lead, Total "As Received"</i>											
Lead	<	2.00	2.00	ug/L	1.00	1	JD2	04/15/26	1845	2976417	1

The following Prep Methods were performed:

Method	Description	Analyst	Date	Time	Prep Batch
EPA 200.2	ICP-MS 200.2 PREP	ES3	04/13/26	1000	2976416

The following Analytical Methods were performed:

Method	Description	Analyst Comments
1	EPA 200.8	

GEL LABORATORIES LLC

2040 Savage Road Charleston SC 29407 - (843) 556-8171 - www.gel.com

Certificate of Analysis

Company : 120Water
Address : 250 South Elm St.
Zionsville, Indiana 46077

Report Date: April 17, 2026

Contact: Justin Calhoun
Project: **Virginia Department of Health**

Client Sample ID: 499585
Sample ID: 772045006
Matrix: Drinking Water (Potable)
Collect Date: 02-APR-26 07:26
Receive Date: 09-APR-26
Collector: Client

Project: 120W00624
Client ID: 120W002

Parameter	Qualifier	Result	RL	Units	PF	DF	Analyst	Date	Time	Batch	Method
Metals Analysis-ICP-MS											
<i>Lead, Total "As Received"</i>											
Lead	<	2.00	2.00	ug/L	1.00	1	JD2	04/15/26	1847	2976417	1

The following Prep Methods were performed:

Method	Description	Analyst	Date	Time	Prep Batch
EPA 200.2	ICP-MS 200.2 PREP	ES3	04/13/26	1000	2976416

The following Analytical Methods were performed:

Method	Description	Analyst Comments
1	EPA 200.8	

GEL LABORATORIES LLC

2040 Savage Road Charleston SC 29407 - (843) 556-8171 - www.gel.com

Certificate of Analysis

Company : 120Water
Address : 250 South Elm St.
Zionsville, Indiana 46077

Report Date: April 17, 2026

Contact: Justin Calhoun
Project: **Virginia Department of Health**

Client Sample ID: 499586
Sample ID: 772045007
Matrix: Drinking Water (Potable)
Collect Date: 02-APR-26 07:27
Receive Date: 09-APR-26
Collector: Client

Project: 120W00624
Client ID: 120W002

Parameter	Qualifier	Result	RL	Units	PF	DF	Analyst	Date	Time	Batch	Method
Metals Analysis-ICP-MS											
<i>Lead, Total "As Received"</i>											
Lead		9.69	2.00	ug/L	1.00	1	JD2	04/15/26	1848	2976417	1

The following Prep Methods were performed:

Method	Description	Analyst	Date	Time	Prep Batch
EPA 200.2	ICP-MS 200.2 PREP	ES3	04/13/26	1000	2976416

The following Analytical Methods were performed:

Method	Description	Analyst Comments
1	EPA 200.8	

GEL LABORATORIES LLC

2040 Savage Road Charleston SC 29407 - (843) 556-8171 - www.gel.com

Certificate of Analysis

Company : 120Water
Address : 250 South Elm St.
Zionsville, Indiana 46077

Report Date: April 17, 2026

Contact: Justin Calhoun
Project: **Virginia Department of Health**

Client Sample ID: 499587
Sample ID: 772045008
Matrix: Drinking Water (Potable)
Collect Date: 02-APR-26 07:28
Receive Date: 09-APR-26
Collector: Client

Project: 120W00624
Client ID: 120W002

Parameter	Qualifier	Result	RL	Units	PF	DF	Analyst	Date	Time	Batch	Method
Metals Analysis-ICP-MS											
<i>Lead, Total "As Received"</i>											
Lead	<	2.00	2.00	ug/L	1.00	1	JD2	04/15/26	1849	2976417	1

The following Prep Methods were performed:

Method	Description	Analyst	Date	Time	Prep Batch
EPA 200.2	ICP-MS 200.2 PREP	ES3	04/13/26	1000	2976416

The following Analytical Methods were performed:

Method	Description	Analyst Comments
1	EPA 200.8	

GEL LABORATORIES LLC

2040 Savage Road Charleston SC 29407 - (843) 556-8171 - www.gel.com

Certificate of Analysis

Company : 120Water
Address : 250 South Elm St.
Zionsville, Indiana 46077

Report Date: April 17, 2026

Contact: Justin Calhoun
Project: **Virginia Department of Health**

Client Sample ID: 499588
Sample ID: 772045009
Matrix: Drinking Water (Potable)
Collect Date: 02-APR-26 07:28
Receive Date: 09-APR-26
Collector: Client

Project: 120W00624
Client ID: 120W002

Parameter	Qualifier	Result	RL	Units	PF	DF	Analyst	Date	Time	Batch	Method
Metals Analysis-ICP-MS											
<i>Lead, Total "As Received"</i>											
Lead	<	2.00	2.00	ug/L	1.00	1	JD2	04/15/26	1850	2976417	1

The following Prep Methods were performed:

Method	Description	Analyst	Date	Time	Prep Batch
EPA 200.2	ICP-MS 200.2 PREP	ES3	04/13/26	1000	2976416

The following Analytical Methods were performed:

Method	Description	Analyst Comments
1	EPA 200.8	

GEL LABORATORIES LLC

2040 Savage Road Charleston SC 29407 - (843) 556-8171 - www.gel.com

Certificate of Analysis

Company : 120Water
Address : 250 South Elm St.
Zionsville, Indiana 46077

Report Date: April 17, 2026

Contact: Justin Calhoun
Project: **Virginia Department of Health**

Client Sample ID: 499589
Sample ID: 772045010
Matrix: Drinking Water (Potable)
Collect Date: 02-APR-26 07:29
Receive Date: 09-APR-26
Collector: Client

Project: 120W00624
Client ID: 120W002

Parameter	Qualifier	Result	RL	Units	PF	DF	Analyst	Date	Time	Batch	Method
Metals Analysis-ICP-MS											
<i>Lead, Total "As Received"</i>											
Lead	<	2.00	2.00	ug/L	1.00	1	JD2	04/15/26	1852	2976417	1

The following Prep Methods were performed:

Method	Description	Analyst	Date	Time	Prep Batch
EPA 200.2	ICP-MS 200.2 PREP	ES3	04/13/26	1000	2976416

The following Analytical Methods were performed:

Method	Description	Analyst Comments
1	EPA 200.8	

GEL LABORATORIES LLC

2040 Savage Road Charleston SC 29407 - (843) 556-8171 - www.gel.com

Certificate of Analysis

Company : 120Water
Address : 250 South Elm St.
Zionsville, Indiana 46077

Report Date: April 17, 2026

Contact: Justin Calhoun
Project: **Virginia Department of Health**

Client Sample ID: 499590
Sample ID: 772045011
Matrix: Drinking Water (Potable)
Collect Date: 02-APR-26 07:30
Receive Date: 09-APR-26
Collector: Client

Project: 120W00624
Client ID: 120W002

Parameter	Qualifier	Result	RL	Units	PF	DF	Analyst	Date	Time	Batch	Method
Metals Analysis-ICP-MS											
<i>Lead, Total "As Received"</i>											
Lead	<	2.00	2.00	ug/L	1.00	1	JD2	04/15/26	1853	2976417	1

The following Prep Methods were performed:

Method	Description	Analyst	Date	Time	Prep Batch
EPA 200.2	ICP-MS 200.2 PREP	ES3	04/13/26	1000	2976416

The following Analytical Methods were performed:

Method	Description	Analyst Comments
1	EPA 200.8	

GEL LABORATORIES LLC

2040 Savage Road Charleston SC 29407 - (843) 556-8171 - www.gel.com

Certificate of Analysis

Company : 120Water
Address : 250 South Elm St.
Zionsville, Indiana 46077

Report Date: April 17, 2026

Contact: Justin Calhoun
Project: **Virginia Department of Health**

Client Sample ID: 499591
Sample ID: 772045012
Matrix: Drinking Water (Potable)
Collect Date: 02-APR-26 07:31
Receive Date: 09-APR-26
Collector: Client

Project: 120W00624
Client ID: 120W002

Parameter	Qualifier	Result	RL	Units	PF	DF	Analyst	Date	Time	Batch	Method
Metals Analysis-ICP-MS											
<i>Lead, Total "As Received"</i>											
Lead	<	2.00	2.00	ug/L	1.00	1	JD2	04/15/26	1900	2976417	1

The following Prep Methods were performed:

Method	Description	Analyst	Date	Time	Prep Batch
EPA 200.2	ICP-MS 200.2 PREP	ES3	04/13/26	1000	2976416

The following Analytical Methods were performed:

Method	Description	Analyst Comments
1	EPA 200.8	

GEL LABORATORIES LLC

2040 Savage Road Charleston SC 29407 - (843) 556-8171 - www.gel.com

Certificate of Analysis

Company : 120Water
Address : 250 South Elm St.
Zionsville, Indiana 46077

Report Date: April 17, 2026

Contact: Justin Calhoun
Project: **Virginia Department of Health**

Client Sample ID: 499592 Project: 120W00624
Sample ID: 772045013 Client ID: 120W002
Matrix: Drinking Water (Potable)
Collect Date: 02-APR-26 07:31
Receive Date: 09-APR-26
Collector: Client

Parameter	Qualifier	Result	RL	Units	PF	DF	Analyst	Date	Time	Batch	Method
Metals Analysis-ICP-MS											
<i>Lead, Total "As Received"</i>											
Lead	<	2.00	2.00	ug/L	1.00	1	JD2	04/15/26	1902	2976417	1

The following Prep Methods were performed:

Method	Description	Analyst	Date	Time	Prep Batch
EPA 200.2	ICP-MS 200.2 PREP	ES3	04/13/26	1000	2976416

The following Analytical Methods were performed:

Method	Description	Analyst Comments
1	EPA 200.8	

GEL LABORATORIES LLC

2040 Savage Road Charleston SC 29407 - (843) 556-8171 - www.gel.com

Certificate of Analysis

Company : 120Water
Address : 250 South Elm St.
Zionsville, Indiana 46077

Report Date: April 17, 2026

Contact: Justin Calhoun
Project: **Virginia Department of Health**

Client Sample ID: 499593
Sample ID: 772045014
Matrix: Drinking Water (Potable)
Collect Date: 02-APR-26 07:32
Receive Date: 09-APR-26
Collector: Client

Project: 120W00624
Client ID: 120W002

Parameter	Qualifier	Result	RL	Units	PF	DF	Analyst	Date	Time	Batch	Method
Metals Analysis-ICP-MS											
<i>Lead, Total "As Received"</i>											
Lead	<	2.00	2.00	ug/L	1.00	1	JD2	04/15/26	1903	2976417	1

The following Prep Methods were performed:

Method	Description	Analyst	Date	Time	Prep Batch
EPA 200.2	ICP-MS 200.2 PREP	ES3	04/13/26	1000	2976416

The following Analytical Methods were performed:

Method	Description	Analyst Comments
1	EPA 200.8	

GEL LABORATORIES LLC

2040 Savage Road Charleston SC 29407 - (843) 556-8171 - www.gel.com

Certificate of Analysis

Company : 120Water
Address : 250 South Elm St.
Zionsville, Indiana 46077

Report Date: April 17, 2026

Contact: Justin Calhoun
Project: **Virginia Department of Health**

Client Sample ID: 499594
Sample ID: 772045015
Matrix: Drinking Water (Potable)
Collect Date: 02-APR-26 07:33
Receive Date: 09-APR-26
Collector: Client

Project: 120W00624
Client ID: 120W002

Parameter	Qualifier	Result	RL	Units	PF	DF	Analyst	Date	Time	Batch	Method
Metals Analysis-ICP-MS											
<i>Lead, Total "As Received"</i>											
Lead	<	2.00	2.00	ug/L	1.00	1	JD2	04/15/26	1904	2976417	1

The following Prep Methods were performed:

Method	Description	Analyst	Date	Time	Prep Batch
EPA 200.2	ICP-MS 200.2 PREP	ES3	04/13/26	1000	2976416

The following Analytical Methods were performed:

Method	Description	Analyst Comments
1	EPA 200.8	

GEL LABORATORIES LLC

2040 Savage Road Charleston SC 29407 - (843) 556-8171 - www.gel.com

Certificate of Analysis

Company : 120Water
Address : 250 South Elm St.
Zionsville, Indiana 46077

Report Date: April 17, 2026

Contact: Justin Calhoun
Project: **Virginia Department of Health**

Client Sample ID: 499595
Sample ID: 772045016
Matrix: Drinking Water (Potable)
Collect Date: 02-APR-26 07:34
Receive Date: 09-APR-26
Collector: Client

Project: 120W00624
Client ID: 120W002

Parameter	Qualifier	Result	RL	Units	PF	DF	Analyst	Date	Time	Batch	Method
Metals Analysis-ICP-MS											
<i>Lead, Total "As Received"</i>											
Lead	<	2.00	2.00	ug/L	1.00	1	JD2	04/15/26	1906	2976417	1

The following Prep Methods were performed:

Method	Description	Analyst	Date	Time	Prep Batch
EPA 200.2	ICP-MS 200.2 PREP	ES3	04/13/26	1000	2976416

The following Analytical Methods were performed:

Method	Description	Analyst Comments
1	EPA 200.8	

GEL LABORATORIES LLC

2040 Savage Road Charleston, SC 29407 - (843) 556-8171 - www.gel.com

QC Summary

Report Date: April 17, 2026

Page 1 of 2

120Water
250 South Elm St.
Zionsville, Indiana
Contact: Justin Calhoun

Workorder: 772045

Parmname	NOM	Sample	Qual	QC	Units	RPD/D%	REC%	Range	Anlst	Date	Time
Metals Analysis - ICPMS											
Batch	2976417										
QC1206433935		772045001	DUP								
Lead	U	ND	U	ND	ug/L	N/A			JD2	04/15/26	18:35
QC1206433938		772045011	DUP								
Lead	U	ND	U	ND	ug/L	N/A				04/15/26	18:54
QC1206433934		LCS									
Lead	50.0			50.9	ug/L		102	(85%-115%)		04/15/26	18:33
QC1206433933		MB									
Lead			U	ND	ug/L					04/15/26	18:31
QC1206433936		772045001	MS								
Lead	50.0	U	ND	48.4	ug/L		96.8	(75%-125%)		04/15/26	18:36
QC1206433939		772045011	MS								
Lead	50.0	U	ND	50.0	ug/L		99.9	(75%-125%)		04/15/26	18:55
QC1206433937		772045001	SDILT								
Lead	U	ND	U	ND	ug/L	N/A		(0%-10%)		04/15/26	18:38
QC1206433940		772045011	SDILT								
Lead	U	ND	U	ND	ug/L	N/A		(0%-10%)		04/15/26	18:57

Notes:

The Qualifiers in this report are defined as follows:

U U Analyte was analyzed for, but not detected above the MDL, MDA, MDC or LOD.

GEL LABORATORIES LLC

2040 Savage Road Charleston, SC 29407 - (843) 556-8171 - www.gel.com

QC Summary

Workorder: 772045

Page 2 of 2

<u>Parmname</u>	<u>NOM</u>	<u>Sample Qual</u>	<u>QC</u>	<u>Units</u>	<u>RPD/D%</u>	<u>REC%</u>	<u>Range</u>	<u>Anlst</u>	<u>Date</u>	<u>Time</u>
-----------------	------------	--------------------	-----------	--------------	---------------	-------------	--------------	--------------	-------------	-------------

N/A indicates that spike recovery limits do not apply when sample concentration exceeds spike conc. by a factor of 4 or more or %RPD not applicable.

^ The Relative Percent Difference (RPD) obtained from the sample duplicate (DUP) is evaluated against the acceptance criteria when the sample is greater than five times (5X) the contract required detection limit (RL). In cases where either the sample or duplicate value is less than 5X the RL, a control limit of +/- the RL is used to evaluate the DUP result.

* Indicates that a Quality Control parameter was not within specifications.

For PS, PSD, and SDILT results, the values listed are the measured amounts, not final concentrations.

Where the analytical method has been performed under NELAP certification, the analysis has met all of the requirements of the NELAC standard unless qualified on the QC Summary.

772045

Chain of Custody

Chain of Custody (CoC) Instructions: The CoC is an official record that accounts for your water samples and must be filled out. You can either collect samples with your 120Water account or by using this form. If you collect samples within your 120Water account, simply fill out section 1 and use return to lab shipping label included in kit and drop kit off at post office. If you use this form to collect samples, fill out both sections 1 and 2, make sure to write down the time you collected each sample and then use return to lab shipping label included in kit and drop kit off at post office. Have questions? Call **800.674.7961** or email **sampling@120water.com**

Facility Name: Clintwood Center
Facility ID: 11867
Sample Event ID: 13914
Account ID: 4394

SECTION 1 MUST BE COMPLETED (even if you collect samples with your 120Water account)

Sampling Date (MM/DD/YYYY): 04.02.2026
Sample Collector's Email: tgenty@kidscentralinc.com
Sample Collector(s) Name (s) (Please Print): Terry Gentry
Sample Collector's Phone: 276-679-0518
Sample Collector(s) Signature: *Terry Gentry*
When was water last used in the building? DATE: 4/1/2026 TIME: 4:00 PM

Did you collect samples within your 120Water account? YES NO, I will use this form

SECTION 2 (NEXT PAGE) MUST BE COMPLETED IF YOU USE THIS FORM TO COLLECT SAMPLES

If you use this form to collect samples (instead of collecting within the 120Water platform) you must write the time each sample was collected in Section 2.

Lab Use Only

RECEIVED IN LAB BY: <i>Mchelle Atemer</i>	DATE: 4/9/26	TIME:	Matrix: DW-Lead
WORK ORDER:			Analyte: Total Lead
Lab Reporting: Email EDD to results@120water.com			Sample Type: Grab

Section 2 (Starting Here) Must be Completed if you use this Form to Collect Samples - Facility Code: CDC 1105

Sample Code	Fixture Code	Sample Type	Location	Location Description	Fixture Type	Time Sample Collected	AM/PM	Notes
499580	CW101	Initial	PY Classroom- sink between bathrooms	Hand washing sink located between bathrooms	Faucet, Cold	7:23	PM	
499581	CW101	Flush	PY Classroom- sink between bathrooms	Hand washing sink located between bathrooms	Faucet, Cold	7:24	PM	
499582	CW102	Initial	Bathroom on right side	Sink located in right bathroom	Faucet, Cold	7:24	AM	
499583	CW102	Flush	Bathroom on right side	Sink located in right bathroom	Faucet, Cold	7:25	AM	
499584	CW103	Initial	Bathroom on left side.	Sink located inside left bathroom	Faucet, Cold	7:25	AM	
499585	CW103	Flush	Bathroom on left side.	Sink located inside left bathroom	Faucet, Cold	7:26	AM	
499586	CW104	Initial	Kitchen Dish Sink	Dish washing sink in kitchen	Faucet, Cold	7:27	AM	
499587	CW104	Flush	Kitchen Dish Sink	Dish washing sink in kitchen	Faucet, Cold	7:28	AM	
499588	CW105	Initial	Kitchen Hand Sink	Handwashing sink located in kitchen	Faucet, Cold	7:28	AM	
499589	CW105	Flush	Kitchen Hand Sink	Handwashing sink located in kitchen	Faucet, Cold	7:29	AM	

Section 2 (Starting Here) Must be Completed if you use this Form to Collect Samples - Facility Code: CDC 1105

Sample Code	Fixture Code	Sample Type	Location	Location Description	Fixture Type	Time Sample Collected	AM/PM	Notes
499590	CW106	Initial	Classroom sink between bathroom in FY classroom	Sink located between bathroom in full year	Faucet, Cold	7:30	AM	
499591	CW106	Flush	Classroom sink between bathroom in FY classroom	Sink located between bathroom in full year	Faucet, Cold	7:31	AM	
499592	CW107	Initial	Bathroom Sink in left bathroom	Sink located in left bathroom in full year cl	Faucet, Cold	7:31	AM	
499593	CW107	Flush	Bathroom Sink in left bathroom	Sink located in left bathroom in full year cl	Faucet, Cold	7:32	AM	
499594	CW108	Initial	Bathroom sink in right bathroom.	Sink located in right side bathroom in full y	Faucet, Cold	7:33	AM	
499595	CW108	Flush	Bathroom sink in right bathroom.	Sink located in right side bathroom in full y	Faucet, Cold	7:34	AM	



Laboratories LLC

SAMPLE RECEIPT & REVIEW FORM

Client: 120W SDG/AR/COC/Work Order: 772045 GEL PM:

Received By: MLS Date Received at GEL: 4-09-20

Carrier (Circle Applicable) FedEx Express FedEx Ground UPS Field Services Courier Client Other USPS IR Temp gun # IR1-25 Daily Calibration Performed Y/N

Table with 4 columns: Tracking Number, Temp (C), If over 6 °C, check if samples do not require cold preservation (for radionuclides only), Tracking Number, Temp (C), If over 6 °C, check if samples do not require cold preservation (for radionuclides only). Row 1: 19, checkmark.

Suspected Hazard Information section with Yes/No columns and questions A) through E) regarding shipping, labeling, and SDS.

Sample Receipt Criteria table with 4 columns: Yes, NA, No, Comments/Qualifiers (Required for Non-Conforming Items). Rows 1-12 covering shipping, preservation, and labeling.

Comments: [Blank area for handwritten notes]

PM (or PMA) review: Initials km Date 4/13/20

Continuation Form Required when selected

Metals
Technical Case Narrative
120 Water Inc.
SDG #: 772045

Product: Determination of Metals by ICP-MS

Analytical Method: EPA 200.8

Analytical Procedure: GL-MA-E-014 REV# 37

Analytical Batch: 2976417

Preparation Method: EPA 200.2

Preparation Procedure: GL-MA-E-016 REV# 20

Preparation Batch: 2976416

The following samples were analyzed using the above methods and analytical procedure(s).

<u>GEL Sample ID#</u>	<u>Client Sample Identification</u>
772045001	499580
772045002	499581
772045003	499582
772045004	499583
772045005	499584
772045006	499585
772045007	499586
772045008	499587
772045009	499588
772045010	499589
772045011	499590
772045012	499591
772045013	499592
772045014	499593
772045015	499594
772045016	499595
1206433933	Method Blank (MB)ICP-MS Batch 2976417
1206433934	Laboratory Control Sample (LCS)
1206433937	772045001(499580L) Serial Dilution (SD)
1206433940	772045011(499590L) Serial Dilution (SD)
1206433935	772045001(499580D) Sample Duplicate (DUP)
1206433938	772045011(499590D) Sample Duplicate (DUP)
1206433936	772045001(499580S) Matrix Spike (MS)
1206433939	772045011(499590S) Matrix Spike (MS)

The samples in this SDG were analyzed on an "as received" basis.

Data Summary:

All sample data provided in this report met the acceptance criteria specified in the analytical methods and procedures for initial calibration, continuing calibration, instrument controls and process controls where applicable, with the following exceptions.

Calibration Information

ICSA/ICSAB Statement

For the ICP-MS analysis, the ICSA solution contains analyte concentrations which are verified trace impurities

indigenous to the purchased standard.

Miscellaneous Information

Additional Comments

Turbidity measurement was recorded as less than 1 NTU, indicating that digestion was not required per method specifications. As such, digestion was not performed. All relevant data has been documented within the preparation batch record to support analysis

Certification Statement

Where the analytical method has been performed under NELAP certification, the analysis has met all of the requirements of the NELAC standard unless otherwise noted in the analytical case narrative.

List of current GEL Certifications as of 17 April 2026

State	Certification
Alabama	42200
Alaska	17-018
Alaska Drinking Water	SC00012
Arkansas	88-00651
CLIA	42D0904046
California	2940
Colorado	SC00012
Connecticut	PH-0169
DoD ELAP/ ISO17025 A2LA	2567.01
Florida NELAP	E87156
Foreign Soils Permit	525-24-281-19660
Georgia	SC00012
Georgia SDWA	967
Hawaii	SC00012
Idaho	SC00012
Illinois NELAP	200029
Indiana	C-SC-01
Kansas NELAP	E-10332
Kentucky SDWA	KY90129
Kentucky Wastewater	KY90129
Louisiana Drinking Water	LA024
Louisiana NELAP	03046 (AI33904)
Maine	2025022
Maryland	270
Massachusetts	M-SC012
Massachusetts PFAS Approval	Letter
Michigan	9976
Mississippi	SC00012
Nebraska	NE-OS-26-13
Nevada	NV-C24-00175
New Hampshire NELAP	205424
New Jersey NELAP	SC002
New Mexico	SC00012
New York NELAP	11501
North Carolina	233
North Carolina SDWA	45709
North Dakota	R-158
Oklahoma	2026-139
Pennsylvania NELAP	68-00485
Puerto Rico	SC00012
S. Carolina Radiochem	10120002
Sanitation Districts of LA	9255651
South Carolina Chemistry	10120001
Tennessee	TN 02934
Texas NELAP	T104704235
Utah NELAP	SC000122026-50
Vermont	VT87156
Virginia NELAP	460202
Washington	C780